

LOCATION 1513 W. 5th St CITY Gaslonis
BETWEEN Yates STREET & Gray STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>1'</u>	<u>6-24-98</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>				
PROP. LINE TO BLDG.	<u>1"</u>	<u>"</u>				


ENTERS: 1513 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 18' S. of CO
5th St

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GP
MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 11-15-90

DEPTH: 1 FT. 6 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:
Purged & tested & Renewed 38' Ext 3/4 P. Ser.

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		