


LOCATION 1804 N. 5TH Ave CITY GASTONIABETWEEN Sherman St STREET & Hampton St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>33'</u>	<u>10-17-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>35'</u>			

ENTERS: 1804 BRANCHED INTO:TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 71' N. of Center of
N. 5TH AvePRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HoffmuthPIPE SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996DEPTH: 1 FT. 6 IN. LOCATION 141' NE of center of Sherman St"A" P/S READING ? TOTAL ANODES 1# 0 17# 0 L.R. # 580870

REMARKS:

	Test Station			ENG. DEPT USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>		