

LOCATION 1806 W. 5TH Ave. CITY GASTONIA

BETWEEN Sherman St. STREET & Hampton St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4'</u>	<u>P</u>	<u>108'</u>	<u>10-17-96</u>		
MAIN TO PROP. LINE	<u>3/4'</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4'</u>	<u>P</u>	<u>73'</u>			

ENTERS: 1806 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 141' NE of center of Sherman St


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huff 8/2/96

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT. 0 IN. LOCATION 11' SE of center of W. 5TH Ave

"A" P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 L.R. # 580872

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY