

LOCATION 2020 W 5th Ave. CITY Gastonia
BETWEEN Heathwood ct STREET & Sherman st STREET


Service	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	90'	11/7/00		
MAIN TO PROP LINE	3/4"	P	50'	"		
PROP LINE TO BLDG	3/4"	P	40'	"		

ENTERS 2020 W. 5th Ave. BRANCHED INTO 2016 W. 5th Ave.
TAP SIZE 3/4" PRESSURE 600 PSI _____ INCHES W C LOCATION 220' East of center of Heathwood ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
MAIN-SIZE 3/4 C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 11/7/00
DEPTH 2' FT 0" IN LOCATION 42 Ft. north of center of W. 5th Ave.

"A" P/S READING _____ TOTAL ANODES 1# 0 17# 0 LR # 01003231

REMARKS new plastic 3/4 service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	riser