

LOCATION 2132 W. 5th Ave. CITY Castroville
 BETWEEN LAKEVIEW ST STREET & Myrtle School Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	7/8"	P	105'	3-18-02		
MAIN TO PROP LINE	5/8"	P	35'			
PROP LINE TO BLDG	5/8"	P	70'			

ENTERS 2132 BRANCHED INTO
 TAP SIZE 1/2 PRESSURE 60 PSI 445' W. of center of LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Sick
 MAIN-SIZE 4" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1963

DEPTH 3 FT 0 IN LOCATION 16' S. of center of W 5th Ave

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 LR # A0121838

REMARKS

