

LOCATION 2145 W. 5th Ave CITY Gastonia
BETWEEN Myrtle School Rd. STREET & 1st STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	124'	10-26-00		
MAIN TO PROP LINE	3/4"	P	18'			
PROP LINE TO BLDG	3/4"	P	106'			

ENTERS 2145 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 633' NE. of center of Myrtle School Rd


PRESSURE TEST @ 100 PSI FOR 44 HRS BY SLH

MAIN-SIZE 4" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 14' S. of center of W. 5th Ave

"A" P/S READING .9 TOTAL ANODES 1# 0 17# 1 LR # 1008461

REMARKS

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead White Existing Main	<u>E</u>	