

LOCATION 2521 Firethorn CT CITY Gastonia
BETWEEN TEA Olive DR STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	47'	2.14.02		
MAIN TO PROP LINE	5/8"	P	3'			
PROP LINE TO BLDG	5/8"	P	44'			

ENTERS 2521 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 670' E. of center of TEA Olive DR

PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY SGH
MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 3 FT 0 IN LOCATION 18' S. of center of Firethorn CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 8286

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	