


LOCATION 2602 Firethorn Ct CITY GASTONIA
 BETWEEN Tea Olive Dr STREET & NANDINA Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>76'</u>	<u>11-17-00</u>		
MAIN TO PROP LINE			<u>11'</u>			
PROP LINE TO BLDG			<u>65'</u>			

 ENTERS 2602 Firethorn Ct BRANCHED INTO
 TAP SIZE 3/4 PRESSURE 60 PSI 3/4 INCHES W/C LOCATION 97' South OF
Center OF Tea Olive Dr.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY W. Cook
 MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
 DEPTH 3 FT IN LOCATION 20' EAST OF Center OF Firethorn Ct.

"A" P/S READING TOTAL ANODES 1# 17# LR #

REMARKS Ran New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	