

LOCATION 2603 Firethorn Ct. CITY Gastonia  
BETWEEN Tea Olive Dr. STREET & Nandina Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>125'</u>	<u>1-5-2001</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>7'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>118'</u>	<u>"</u>		

ENTERS 2603 Firethorn Ct. BRANCHED INTO Ø  
TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 103' west


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY P.R. center of Firethorn Ct.

MAIN-SIZE 4" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 19' south of center of Tea Olive Dr.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 0004300

REMARKS new 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>