

LOCATION 2619 Firethorn CT CITY Gastonia

BETWEEN VANDERBILT CT STREET & TEA OLIVE DR STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|-------------|----------|------------|---------------|---------|---------|
| MAIN TO BLDG | <u>3/4"</u> | <u>P</u> | <u>44'</u> | <u>4-9-01</u> | | |
| MAIN TO PROP LINE | <u>5/4"</u> | <u>P</u> | <u>7'</u> | | | |
| PROP LINE TO BLDG | <u>3/4"</u> | <u>P</u> | <u>37'</u> | | | |

ENTERS 2619 BRANCHED INTO 2611

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 72" W. of center of Firethorn CT


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SLK

MAIN SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2007

DEPTH 2 FT 0 IN LOCATION 210' S. of center of Tea Olive Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 6 LR # 254204

REMARKS



| Test Station | | |
|---|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |