

LOCATION 2635 Firethorn CT. CITY BASTONIA

BETWEEN TEA Olive DR STREET & NANDINA CT STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	578"	P	110'	1-9-02		
MAIN TO PROP LINE	578'	P	40'			
PROP LINE TO BLDG	578'	P	70'			

ENTERS 2635 BRANCHED INTO \_\_\_\_\_

TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 425' SW. of center of TEA Olive Dr.


PRESSURE TEST @ 100 PSI FOR 114 HRS BY S.H

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 3 FT 0 IN LOCATION 20' SE. of center of Firithorn CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 144768

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	