


LOCATION 2642 Firethorn Ct. CITY GASTONIA  
 BETWEEN NANDINA Ct. STREET & Tea olive Dr. STREET  

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	1/2"	Plastic	99'	10/18/01		
MAIN TO PROP LINE	1/2"	Plastic	10'			
PROP LINE TO BLDG	1/2"	Plastic	89'			

 ENTERS 2642 BRANCHED INTO 0  
 TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 98' N of Cap Nandina Ct.  
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY DL  
 MAIN SIZE 2" C I          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1999  
 DEPTH 3 FT 6 IN LOCATION 20' E of Cap Firethorn Ct.  
 "A" P/S READING Plastic N/A TOTAL ANODES I# 0 17# 0 LR #         

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic (Galv.)
P/S Pipeline Lead White Existing Main	E	

COPY