

LOCATION 2720 Firethorn Ct. CITY GASTONIA
BETWEEN NANDINA Ct. STREET & End of Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>78'</u>	<u>7-23-01</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>8'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>70'</u>			

ENTERS 2720 BRANCHED INTO 0

TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 363' S of E of Nandina Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 6 IN LOCATION 22' E of E of Firethorn Ct.

"A" P/S READING Plastic n/a TOTAL ANODES I# 0 17# 0 LR # 00586031

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>Plastic</u>