

LOCATION 2306 FIRMIN CT CITY CASTLETON

BETWEEN EASTRIDGE DR. STREET & CELINDA CT. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>140'</u>	<u>1-9-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>100'</u>			

ENTERS 2306 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 135' N. of center of EASTRIDGE DR.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN LOCATION 16' W. of center of FIRMIN CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 8106

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	