

LOCATION 2333 Firmin Ct CITY Gastonia

BETWEEN Belinda Ct STREET & Cal-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	86'	11-10-97		
MAIN TO PROP. LINE	3/4"	P	6'			
PROP. LINE TO BLDG.	3/4"	P	80'			

ENTERS: 2333 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 450' N. of center off

Belinda Ct


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hufstetter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN LOCATION 40' W. of center of Firmin Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 765083

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY