

LOCATION 2002 Flint Ln CITY Cash.
BETWEEN LANE st. STREET & Bryson st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>73'</u>		<u>10-</u>	<u>9-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>27'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>46'</u>			

ENTERS SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 180' From @ OF

Flint Ln


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION S. OF Flint Ln

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY