

LOCATION 802 Florida St CITY Gastonia
BETWEEN 20th STREET & Deadend STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>46'</u>		<u>3-</u>	<u>13-98</u>
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>42'</u>			

ENTERS: 802 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY SE
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998
DEPTH: 4 FT 0 IN LOCATION _____

"A" P/S READING PL TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY