

LOCATION 1513 Florida Ave CITY Gastonia
BETWEEN Hillcrest STREET & Townsend STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	<input checked="" type="checkbox"/> RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>174'</u>			
MAIN TO PROP. LINE	<u>1"</u>	<u>11</u>	<u>45'</u>			<u>1-31-98</u>
PROP. LINE TO BLDG.	<u>1"</u>	<u>11</u>	<u>129'</u>			


ENTERS: 1513 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 14' S. of C of Townsend

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY AP KH
MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 2 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>PR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY