

LOCATION 1605 Florida St CITY GASTON  
BETWEEN CAROLINA STREET & 15th STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PL</u>	<u>2'</u>	<u>Tied over</u>	<u>48' of 3/4 Plastic Service</u>	
MAIN TO PROP. LINE				<u>to new 2"</u>	<u>PL main</u>	
PROP. LINE TO BLDG.					<u>2-7-98</u>	

ENTERS: 1605 BRANCHED INTO: —  
TAP SIZE: 3/4 PRESSURE 100 PSI \_\_\_\_\_ INCHES WC LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SE  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997  
DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING PL TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY