

LOCATION 1611 Florida St CITY CASTORIA

BETWEEN CAROLINA Ave STREET & 19<sup>TH</sup> ST. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>		<u>2-7-98</u>	
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>8'</u>		<u>Retired</u>	<u>95' c/w</u>
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>62'</u>			<u>Service.</u>

ENTERS: 1611 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 126' N. of center of 19<sup>TH</sup> ST.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hurtsteyn

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 12' W. of center of Florida St.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 11689

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY