

LOCATION 1811 Florida St CITY GASTONIA
BETWEEN 20TH STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	49'		3/14/98	3/14/98
MAIN TO PROP. LINE	3/4"		5'			
PROP. LINE TO BLDG.	3/4'		44'			

ENTERS: 1811 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION South side of 1811

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DT
MAIN-SIZE 2' C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1991
DEPTH: 3 FT 0 IN 0 LOCATION West side of Florida St

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY