

LOCATION 1908 Florida StCITY GASTONIABETWEEN JohnsSTREET & DEAD END

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>67'</u>	<u>4-4-98</u>	<u>4-4-98 (85%)</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>25'</u>		<u>3/4" CM</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>42'</u>		<u>orig inst</u>	

ENTERS: 1908BRANCHED INTO: ( )TAP SIZE: 3/4PRESSURE 60 PSI

INCHES W C

LOCATION 10' E of FloridaPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY M. ParkerMAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC X YEAR INSTALLED 1998DEPTH: 3 FT 0 IN LOCATION 154' S of Johns"A" P/S READING PTOTAL ANODES 1#        17#       L.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY