

LOCATION 1920 Florida StCITY GASTONIABETWEEN JohnsSTREET & Dead end

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>83'</u>	<u>4-4-98</u>	<u>4-4-98 (85')</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>20'</u>		<u>3/4" CW</u>	
PROP LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>63'</u>		<u>or 8 INST.</u>	

ENTERS. 1920BRANCHED INTO: ()TAP SIZE. 3/4PRESSURE 60 PSI

INCHES W.C

LOCATION 239' S of JohnsPRESSURE TEST: @ 100 PSI FOR 4 HRS BY M. ParkerMAIN-SIZE 2"C.I. BARE STEEL COATED STEEL PLASTIC KYEAR INSTALLED 1998DEPTH: 3 FT 0 IN.LOCATION 9' E of Florida"A" P/S READING PTOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-1132</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY