


LOCATION 1002 + 606 Flowe St CITY CASPER, WY
 BETWEEN Martha STREET & STREET

	SIZE	TYPE	602 LENGTH 606	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	D	74' 30"			
MAIN TO PROP LINE	3/4	D	30' 5"			9-16-94
PROP LINE TO BLDG	3/4	P	64' 25"			
ENTERS <u>602</u>			BRANCHED INTO <u>606</u>			
TAP SIZE <u>3/4</u>		PRESSURE <u>60</u> PSI		INCHES W C		LOCATION

PRESSURE TEST @ 100 PSI FOR 1 1/2 HRS BY ED
 MAIN SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1967
 DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	<u>1.1</u>
P/S Pipeline Lead White Existing Main	E	