

LOCATION 612 & 610 Flowe St CITY Coastal
BETWEEN Martha STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	126	50'		
MAIN TO PROP LINE	3/4	P	30'	5'		9-16-55
PROP LINE TO BLDG	3/4	P	96'	45'		

ENTERS 612 BRANCHED INTO 610
TAP SIZE 3/4 SM PRESSURE 60 PSI INCHES W C LOCATION

PRESSURE TEST 100 PSI FOR 4 HRS BY ED

MAIN SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1967
DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# 17# LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	Plaster
P/S Pipeline Lead White Existing Main	E	

