

LOCATION 822 FLOYD ST CITY WYOMING
TWEEN 7th STREET & ASHTON STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	ϕ	207'		<input checked="" type="checkbox"/>	
MAIN TO PROP LINE	3/4	ϕ	0			3-19-01
PROP LINE TO BLDG	3/4	ϕ	207			


ENTERS 832 BRANCHED INTO 822
TAP SIZE 3/4 SCH PRESSURE 60 PSI INCHES WC LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 3/4 C I BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED
DEPTH 1 FT 6 IN LOCATION

"A" P/S READING 1.543 TOTAL ANODES 1# 5 17# LR #

REMARKS
Tracer wire tied off at Bell Hole



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	PLASTIC
P/S Pipeline Lead - White Existing Main	E	