

LOCATION 857 Floyd Ln. CITY Pastoria  
BETWEEN W. 7th Ave. STREET & Kalyor Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	85'	4-2-01		
MAIN TO PROP LINE	3/4"	P	34'	"		
PROP LINE TO BLDG	3/4"	P	51'	"		

ENTERS 857 Floyd Ln. BRANCHED INTO Ø  
TAP SIZE 3/8" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 376' north


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.R. center of Kalyor Ct.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1960

DEPTH 3' FT 0" IN LOCATION 13' East of center of Floyd Ln.

"A" P/S READING 1.2 TOTAL ANODES 1# Ø 17# Ø LR # 00223755

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	rise