

LOCATION 900 Floyd Lane CITY Gastonia
BETWEEN 7th STREET & Hooper Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>65'</u>	<u>12-17-97</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>"</u>	<u>59'</u>			

ENTERS: 900 BRANCHED INTO: —
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W C LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY S. Elmore
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1960
DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING 1.4 TOTAL ANODES 1# — 17# — L.R. # 856653

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY