

LOCATION 916 Floyd Ln. CITY GASTON, NC
BETWEEN Hooper Ave. STREET & 7th Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>57'</u>	<u>4-20-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>3'</u>			
PROP LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>54'</u>			


ENTERS: 916 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 498' N. of center of
Hooper Ave.

PRESSURE TEST: @ 100 PSI FOR 14 HRS BY S. HURKSTALL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 14' E. of center of Floyd Ln

"A" P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 L.R. # 236974

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY