

LOCATION 1220 FLOYD LANECITY GASTONIABETWEEN Miller ST.STREET & SPENCER RD.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PL</u>	<u>52' NEW 3/4 PLASTIC</u>		<u>3-6-98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>			<u>Tied ON 11' Existing 3/4</u>	
PROP. LINE TO BLDG	<u>11</u>	<u>11</u>			<u>PLASTIC SERVICE</u>	

ENTERS 1220


BRANCHED INTO

TAP SIZE: 3/4PRESSURE 60 PSI

INCHES W.C.

LOCATION 477'S FROM 9/0F MillerPRESSURE TEST: @ 100 PSI FOR 44 HRS BY BBMAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT 0 IN LOCATION 19' WEST FROM 9/0F FLOYD"A" P/S READING PLTOTAL ANODES 1#        17#       L.R. #       

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>RISER</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY