


LOCATION 1224 FLOYD LANECITY GASTONIABETWEEN Miller ST. STREET & SPENCER Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PL</u>	<u>41</u>			<u>3-6-98</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>3</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>38</u>			

ENTERS: 1224BRANCHED INTO —TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 524'S FROM % OF MillerPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BBMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1997DEPTH. 3 FT 0 IN LOCATION 19' W FROM % OF FLOYD"A" P/S READING PL TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>RI SER</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY