

LOCATION 3024 Forbes Rd. CITY QASTONIA

BETWEEN LITTLE MTN. RD. STREET & Todd Reese Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	134'	10-30-97		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	94'			

ENTERS: 3024 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 345' SW. of center of

LITTLE MTN. RD.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. HURST/ATL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN. LOCATION 13' NW. of center of Forbes Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 743560

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY