


LOCATION 607 Forest DriveCITY GASTONIABETWEEN Union Rd.STREET & Fern Forest Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>108'</u>	<u>11-13-56</u>	<u>5-30-94</u>	<u>5-30-94</u>
MAIN TO PROP. LINE					<u>3/4" Bare 88'</u>	
PROP. LINE TO BLDG.					<u>Service</u>	

ENTERS: 607BRANCHED INTO: 605TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 284' E of C of Union Rd.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 2" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1956DEPTH: 3 Ft. 0 In. LOCATION 23' S of C of Fern Forest Dr."A" P/S READING .04 TOTAL ANODES 1# _____ 17# 1 L.R. # _____REMARKS: Retired 3/4 Bare Service, Renewed with New 3/4 Plastic

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY