

LOCATION 717 Forest Dr. CITY Gastonia
BETWEEN Tanglewood Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>82'</u>			<u>1-21-97</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>62'</u>			

ENTERS: SAME BRANCHED INTO.

TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 288' From @ OF
Tanglewood


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.H.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION South side of forest Dr.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY