

LOCATION 718 forest Dr. CITY EAST.

BETWEEN Tanglewood Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PL.</u>	<u>125'</u>		<u>1-21-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>42'</u>			
PROP. LINE TO BLDG	<u>"</u>	<u>"</u>	<u>83'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 300' from @ of

Tanglewood Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.H./

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 2 IN LOCATION Southside of forest Dr.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY