

LOCATION 726 Forest Dr. CITY Gastonia

BETWEEN Tanglewood Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>157'</u>			<u>1-22-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>112'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 364' From @ of

Tanglewood Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.H.F.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION Southside of Forest Dr.

"A" P/S READING P. TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY