

LOCATION 1017 Forestbrook Dr. CITY Gastonia

BETWEEN Sherwood Dr STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	93'	3-10-95		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	88'			

ENTERS: 1017 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION 645' N. of center of

Sherwood Dr


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Whitfield

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1974

DEPTH: 3 Ft. 0 In. LOCATION 21' W. of center of Forestbrook Dr

"A" P/S READING .9 TOTAL ANODES 1# 0 17# 0 L.R. # 82859

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY