

LOCATION 3213 Forest Creek CT CITY Gastonia
BETWEEN Strong Box Lw. STREET & Huntingwood CT STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>105'</u>	<u>2.13-02</u>		
MAIN TO PROP. LINE	<u>5/8"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>65'</u>			

ENTERS 3213 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 266' N. of center of Huntingwood CT


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SLK

MAIN SIZE 3" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 19' E. of center of Forest Creek CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 26879

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	