

LOCATION 3221 FOREST CREEK CT CITY GASTONIA  
BETWEEN HUNTING WOOD CT STREET & STRONG BOX LN. STREET

|                   | SIZE        | TYPE     | LENGTH     | INSTALLED       | RETIRED | RENEWED |
|-------------------|-------------|----------|------------|-----------------|---------|---------|
| MAIN TO BLDG      | <u>5/8"</u> | <u>P</u> | <u>101</u> | <u>11.17.01</u> |         |         |
| MAIN TO PROP LINE | <u>"</u>    | <u>"</u> | <u>39</u>  |                 |         |         |
| PROP LINE TO BLDG | <u>"</u>    | <u>"</u> | <u>62</u>  |                 |         |         |

ENTERS 3221 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION S side of 3221

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Tim  
MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC / YEAR INSTALLED 2001

DEPTH 3 FT IN LOCATION E side of FOREST CREEK

"A" P/S READING N/A TOTAL ANODES 1# 17# LR #

REMARKS

