

LOCATION 3229 Forest Creek Ct. CITY Gastonia
BETWEEN Strong box lane STREET & Huntingwood Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	104'	5-13-02		
MAIN TO PROP LINE	5/8"	P	42'	"		
PROP LINE TO BLDG	5/8"	P	62'	"		

ENTERS 3229 BRANCHED INTO Ø

TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 104' north of center of Huntingwood Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody


MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 10/2001

DEPTH 3' FT 0" IN LOCATION 20' East of center of Forest Creek Ct.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 00124299

REMARKS New Plastic Service

(Rd Box)



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	rise