

LOCATION 3253 Forest Creek Ct. CITY San Antonio
BETWEEN Huntingwood Ct. STREET & End of Caldesack. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>PLASTIC</u>	<u>135'</u>	<u>9-10-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>PLASTIC</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>PLASTIC</u>	<u>90'</u>			


ENTERS 3253 BRANCHED INTO 0
TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 100' W of C of Huntingwood Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 3 FT 8 IN LOCATION 20' N of C of Forest Creek Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>