

LOCATION 3268 Forest Creek Ct CITY Gastonia
BETWEEN Hunting Wood Ct STREET & Strong Box Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>108'</u>	<u>6-18-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>98'</u>	<u>"</u>		

ENTERS 3268 BRANCHED INTO Ø
TAP SIZE 1 1/2" PRESSURE 60 PSI INCHES W C LOCATION 185' East


PRESSURE TEST @ 100 PSI FOR 1 1/2 HRS BY center of Hunting Wood Ct.

MAIN-SIZE 2" C I Ø BARE STEEL Ø COATED STEEL Ø PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3' FT 2" IN LOCATION 39' North of center of Forest Creek Ct

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 00483735

REMARKS New 3/4" Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic riser
P/S Pipeline Lead - White Existing Main	E	