

LOCATION 210 FOREST HILL CITY EAST.BETWEEN TENTH AVE. STREET & Hillside Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>37' TIE OVER</u>			<u>4-14-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>"</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>"</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 250' From @ ofTENTH AVE.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DNFMAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN LOCATION South side of Forest Hill"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY