


LOCATION 607 W 4th st. CITY Easton PA
 BETWEEN S. Clay st STREET & Trenton st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>55'</u>	<u>3-26-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>50'</u>	<u>"</u>		

ENTERS 607 W 4th st. BRANCHED INTO 0
 TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 255' East
of center of Trenton st.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.R.
 MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991
 DEPTH 3' FT 0" IN LOCATION 12' north of center of W. 4th st.
 "A" P/S READING 1114 TOTAL ANODES 1# 0 17# 0 LR # 00221831
 REMARKS New 3/4 P. Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	115v