

LOCATION 1011 W 4th Ave. CITY Columbus
BETWEEN Weldon STREET & Dalton STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>53'</u>	<u>4-4-03</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>6'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>47'</u>	<u>"</u>		

ENTERS 1011 BRANCHED INTO 0

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 301' West


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Wootley
of center of Weldon str

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1991

DEPTH 3' FT 0" IN LOCATION 14' south of center of W 4th Ave.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00080668

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>rise</u>