

LOCATION 1116 W. FourthCITY GastoniaBETWEEN MillonSTREET & Duffan

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>85'</u>	<u>11-3-98</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>47'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>"</u>	<u>38'</u>			

ENTERS: 1116BRANCHED INTO: —TAP SIZE: 3/8PRESSURE 60


PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JEMAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1977DEPTH: 3 FT. 0 IN. LOCATION"A" P/S READING 1200TOTAL ANODES 1# — 17# —L.R. # 2142832

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>RISER</u>	<u>Ph</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY