

LOCATION 3026 Foxborough CT CITY GASTONIA

BETWEEN River Ridge DR STREET & STREET

|                     | SIZE        | TYPE     | LENGTH     | INSTALLED      | RETIRED | RENEWED |
|---------------------|-------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG.       | <u>3/4"</u> | <u>P</u> | <u>86'</u> | <u>6-14-95</u> |         |         |
| MAIN TO PROP. LINE  | <u>3/4"</u> | <u>P</u> | <u>5'</u>  |                |         |         |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>81'</u> |                |         |         |

ENTERS: 3026 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 172' W. of center of River Ridge DR.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBURN

MAIN-SIZE 3/4" C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 18' N. of center of Foxborough CT

"A" P/S READING 7 TOTAL ANODES 1\* 0 17\* 0 L.R. # 285584

REMARKS:



| Test Station                               |      |       |
|--|------|-------|
| Reading & Location                         | Lead | Volts |
| P/S Pipeline Lead - Red<br>New Service     | S    |       |
| P/S Pipeline Lead - White<br>Existing Main | E    |       |

ENG. DEPT. USE ONLY