

LOCATION 3029 Foxborough Ct CITY Gastonia
BETWEEN River Ridge Ct STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>76'</u>	<u>6-16-94</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>68'</u>			

ENTERS: 3029 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 20' S. of Cof
Foxborough Ct


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By —

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION —

"A" P/S READING P TOTAL ANODES 1* — 17* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY