

LOCATION 3034 Foxborough Ct. CITY Gastonia

BETWEEN River Ridge Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>91'</u>	<u>3-21-95</u>		
MAIN TO PROP. LINE	<u>Ø</u>					
PROP. LINE TO BLDG.						

ENTERS: 3034 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 172' E. of center of

River Ridge Dr


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstuty

MAIN-SIZE 2' C.I.     BARE STEEL     COATED STEEL     PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 20' S. of center of Foxborough Ct.

"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. #    

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		