


LOCATION 3042 Foxborough CtCITY GrotonBETWEEN River Ridge DrSTREET & Deedend

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	113'	2-22-94		
MAIN TO PROP. LINE	3/4	P	5'			
PROP. LINE TO BLDG.	3/4	P	108'			

ENTERS: 3042 Foxborough CtBRANCHED INTO: —TAP SIZE: 1/2 PRESSURE 60 P.S.I. — INCHES W.C. LOCATION 14' E of Foxborough CtPRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. EmmeMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3 Ft. D In. LOCATION 254' N of River Ridge Dr"A" P/S READING P TOTAL ANODES 1\* — 17\* — L.R. # 066046

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY